

INTER-OFFICE CORRESPONDENCE

TO: Town Planning Board

FROM: Town Fire Inspector

SUBJECT: Patriot Estates Subdivision

DATE: December 10, 2001

Planning Board Reference Number: PB-01-66

Dated: 6 December 2001

Fire Prevention Reference Number: FPS-01-067

A review of the above referenced subject subdivision plan was conducted on 7 December 2001, with the following being noted:

- 1) With the number of homes to be built on this project, As well as PB-01-65, it is my opinion that the Park Hill Drive Access roadway is needed in order to have Accessibility to the site at all times and not impeded By any emergency gates.**

This subdivision plan is not acceptable.

Plans Dated: 3 December 2001.

RFR (D.H.)
Robert F. Rodgers